

**NAVFAC  
SPECIFICATION**

**Repairs of Structural Steel  
Columns, Hangar 130**

**AMENDMENT #0001**

## **IMPORTANT**

**This amendment should be acknowledged when your proposal is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the proposal.**

**If your proposal has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your proposal is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to proposal opening time.**

2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 9/06/2011	4. REQUISITION/PURCHASE REQ. ---	5. PROJECT NO. (If applicable)
---------------------------------------	--------------------------------	-------------------------------------	--------------------------------

6. ISSUED BY <b>CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533</b>	Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code
--	-------------	--	------

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)  <b>AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL</b>	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION PROJECT #
	<input type="checkbox"/>	9B. DATED (SEE ITEM 11)
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
	<input type="checkbox"/>	10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers  is extended  is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

---

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor  is not  is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

**MAINTENANCE AND REPAIRS OF STEEL COLUMNS, HANGAR 130 , MARINE CORPS AIR STATION, CHERRY POINT, NORTH CAROLINA**

The purpose of this amendment is to provide the following information:

1. See the continuation page.
2. Proposal due date remains unchanged.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

1. Is the existing paint lead based?

Answer: The existing paint surfaces have tested positive for lead.

2. SW column: the outer most door in this area will need to be removed to remove and install new column. Is current contractor stopping work on bay doors until this contract is completed?

Answer: Due to CCD current contractor will not be stopping work

3. Pg A-3, note states "Metal siding remove & replace under existing contract." Current contractor is about to install in this area. Will he/she be either stopping that work or will they be removing & reinstalling under that contract or is it to be in this contract? If so, please provide specifications.

Answer: Due to tight timeline for building occupants, current contractor will not be stopping work

4. Pg A-4, Detail A3&A4 notes to remove & replace bottom band of T&G wood panels only. T&G is attached to column to be removed. Please advise.

Answer: The intent is to remove enough of the wood siding to allow forming of the cast in place concrete coping. The coping is integral with the support of the base of the siding.