

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE OF PAGES 1 2
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 3/12/10	4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) 090148
6. ISSUED BY NAVFAC MID ATLANTIC OFFICER IN CHARGE OF CONSTRUCTION MARINE CORPS INSTALLATION EAST 1005 MICHAEL ROAD CAMP LEJEUNE, NC 28547-2521		7. ADMINISTERED BY (If other than Item 6) SEE ITEM 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0148
				X	9B. DATED (SEE ITEM 11) 4-Mar-2010
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					1 OB. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR- 43.103(b)
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
090148, Repair the Combat Training Pool, Bldg. 236

SEE CONTINUATION PAGE.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

The purpose of this amendment is to respond to some of the Contractor's RFI questions:

1. Question: Drawing A-1 Demo/Const Note #9 "Contractor to Re-Point and Seal ..."
Please provide a LF quantity for bidding purposes.

Answer 1) Note #9 implies all of the brick surface, approximately 4,760 SF.

2. Question: Drawing A-3 Demo/Const Note #7 "Contractor to Remove and Replace
...500 sf....Typical for all elevations"
Is the total for the building 500 sf or 2000 sf?

Answer 2) The total for the building is approximately 500 SF.

3. Question: Drawing A-2 Note 6 "Demo and remove existing Structural pipe
hangers....."
Drawing A-4 Building Section A/A1/A4 top center note "Contractor to clean/prepare
existing 3" tie rods...."
Are the existing rods and components to be replaced or repainted?

Answer 3) The note on sheet A-4 is incorrect. The intent is to replace existing (vertical) anchors embedded into the roof structure and the (vertical) connection rods. Both of these components are supporting the (horizontal) lateral supports. There are (6) anchors and (6) connection rods per lateral support. The lateral supports are to remain. All components are to be painted.

All other terms and conditions remain unchanged.