

The following changes are made to Parts 2-6 of the RFP:

- (RFI #6) PART 3/CHAPTER 4/PAGE 16
4. BUILDING REQUIREMENTS
4.1 Space Tabulation
Tools and Publications Room 300 SF
- (RFI #8) PART 3/CHAPTER 4/PAGE 16
4. BUILDING REQUIREMENTS
4.1 Space Tabulation
Drum Storage 130 SF
Proposer shall use best engineering practices to accommodate the 10'Hx9'W overhead coiling door. Square footage may be adjusted to accommodate this as long as total square footage allowed is not compromised.
- PART 5/CHAPTER 5/PAGE 26
5. ROOM REQUIREMENTS
Drum Storage, 116
B2030-Exterior Doors- Overhead Coiling Doors-1 each-10'Hx9'W
- (RFI #12) PART 5/CHAPTER 5/PAGE 20
5. ROOM REQUIREMENTS
Vehicle Maintenance Bays, 110, 111, 112
B2030-Exterior Doors- Overhead Coiling Doors-6 each-14'Hx16'W
- (RFI #13) PART 6/DIRECT TV INSTALLATION MANUAL
DELETE FROM RFP
- (RFI #14) PART 4/SECTION E10/EQUIPMENT
1.5 CONSTRUCTION SUBMITTALS/PAGE 2
Field tests of compressed air system, vehicle exhaust system, and the vehicle lube system.

All other terms and conditions remain unchanged. Date and time for receipt of proposals is unchanged.