

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 07/18/11	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 10-0036
6. ISSUED BY CODE rmm Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-10-R-0036
			X	9B. DATED (SEE ITEM 11) 07/06/11
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Project 10-0036, Site Prep for MRAP Egress Trainers
 The time and date for the receipt of proposals remains 1400, Wednesday, 20 July 2011.

See Continuation pages

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

- 1) Question: Metal Building Systems 13 34 19, Spec section 1.2.4 Thermal Performance references insulated panels roof and walls, are we to figure this type panel?

Answer: No insulated panels are required, contractor shall provide blanket insulation.

- 2) Question: Metal Building Systems 13 34 19, Spec section 1.4.7 Roof system references Standing seam vertical rib roof, are we to figure this type panel?

Answer: Contractor shall provide a standing seam metal roof.

- 3) Question: Metal Building Systems 13 34 19, Spec section 1.4.8 Exterior wall system references insulated wall panels, are we to figure this type panel?

Answer: No insulated panels are required, contractor shall provide blanket insulation.

- 4) Question: Metal Building Systems 13 34 19, Spec section 2.3.4 Bracing does not reference rod bracing, can it be used?

Answer: No, contractor shall provide rigid bracing.

- 5) Question: Will we be required to have Super/ SSHO/ QC at each site?

Answer: If both sites are going to be worked concurrently, then YES a Super/ SSHO/ QC is required at each site.

- 6) Question: Specification 13 34 19 para 1.4.8 calls for insulated metal wall panels. Please confirm that the intent is for a metal wall panel and R-19 insulation system and not in fact an "Insulated Panel" unit. There is a very large price differential between the two systems. (Please note that the roof states a standing seam metal roof with insulation.)

Answer: Provide metal siding/roof panels with rolled wall/roof insulation, not insulated wall/roof panels.

- 7) Question: Specification 13 34 19 para 1.10 calls for warranties to be 20 year, para 3.12 provides forms for a 5 year warranty. Please clarify this apparent conflict.

Answer: Provide a 20-year warranty

- 8) Question: Specification 13 34 19 para 2.4.1 is for aluminum sheet panels; drawings do not indicate any aluminum sheet panels. Please advise.

Answer: DELETE Specification 13 34 19, Paragraph 2.4.1 - Aluminum Sheet.

Amendment 0002

Project 10-0036

Page 3 of 3

- 9) Question: Specification 13 34 19 para 2.4.3 is for Insulated panel construction; drawings do not indicate any Insulated panel construction. Please advise.

Answer: Delete Specification 13 34 19 Paragraph 2.4.3 - Insulated Panel Construction.

- 10) Question: In regards to paragraph 3.2 of section 083323 the specifications asks for the coiling doors to be have a field paint finish although the door schedules ask for the coiling doors to match the metal panels, if we were to match the metal panels we would have to price a custom powder coated finish which would be a significant additional cost to the coiling doors, can you verify NAVFAC's intent on the finish for the coiling doors? **We recommend a prime painted finish in grey, white or tan.

Answer: Provide a factory applied primed, painted overhead door with a standard color to be selected via the submittal process.

- 11) Question: The specs state to obtain fill from outside government property. However, the government has been allowing the use of the French Creek Borrow Pit for recent projects. Can the French Creek Borrow Pit be used on this project to obtain fill in quantities needed for this project.

Answer: The French Creek Borrow Pit may be used to obtain fill for this project.