

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003	3. EFFECTIVE DATE 9/15/11	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 11-0117	
6. ISSUED BY CODE	jsy	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-11-R-0117
			X	9B. DATED (SEE ITEM 11) 9/9/11
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.  
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing items 8 and 15, and returning \_\_\_\_\_ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;  
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

11-0117, Repair Applied Instruction Building, BB-50

SEE CONTINUATION SHEET

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

**CONTINUATION SHEET**

**1. Question:** In regards to paragraph 2.1.2 of section 083323 the specification asks for an R-value of 6.84 using a polystyrene insulated slat core, although the highest R-value for a polystyrene insulated coiling door is 4.6, can you verify that this is acceptable?

**1. Answer:** An R value of 4.6 is acceptable.

**2. Question:** In regards to paragraph 2.1.6 of section 083323 the specification asks for both cylinder and slide bolt locks, can you verify which lock type is required for this project?

**2. Answer:** The slide bolt is the preferred mechanism. Delete the following from the specifications, Section 08 33 23, OVERHEAD COILING DOORS, 2.1.6, LOCKING DEVICES, "Locking Device Assembly which includes cylinder lock, spring-loaded dead bolt, operating handle, cam plate, and adjustable locking bars to engage through slots in tracks."

**3.** Demolish existing wet pipe sprinkler system to flange under sprinkler riser.

**4.** Provide new wet pipe sprinkler system. Rooms 100, 101, 102, and 104 shall be ordinary hazard group 2 (0.2 gpm/sf 3000 sf design area and 500 gpm hose stream) The remainder of the building shall be light hazard (.1 gpm/sf 3000 sf design area).

Sprinkler riser: Provide 12" long 6" diameter spool piece from existing flange. Provide 6" 90 degree elbow from spool piece. Provide 6" RPZ assembly with OS&Y valves listed for fire service. Provide drain cup and waste piping through wall for RPZ. Provide 4" backflow test header with 4" gate valve and two 2-1/2" hose connections on outside wall. Provide 4" FDC with 4" check valve, ball drip, and two 2-1/2" hose connections on outside wall. Provide 2" main drain. Provide flow switch. Provide tamper switches on RPZ OS&Y valves. Connect flow and tamper switches to fire alarm system. Size sprinkler piping at or below 6 ft/s water velocity.

**5.** When submitting proposals, Contractor shall provide pricing as follows:

**Under the line items furnished the offers shall state prices for each line item given hereinafter:**

**Priced Line Item 0001**

**Price includes completing all work associated with telecom work. \$ \_\_\_\_\_**

**Priced Line Item 0002**

**Price includes all work other than that listed in line item 0001. \$ \_\_\_\_\_**

**TOTAL Priced Line Items 0001 & 0002. \$ \_\_\_\_\_**

N40085-11-R-0117

Amendment 0003

Page 3 of 3

**Award will be based on the total of Priced Line items 0001 & 0002.**

**Notes\***

**A. Offers must be submitted on all items. Failure to propose on all items may result in the offer being rejected as non-responsive. Award will be made on the total sum of Priced Line Item 0001 & 0002.**