

| | | | | |
|--|----------------------------------|---|---|-------------------------------------|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | | 1. CONTRACT ID CODE J | PAGE OF PAGES 1 4 |
| 2. AMENDMENT/MODIFICATION NO. 0003 | 3. EFFECTIVE DATE 12-Jan-2012 | 4. REQUISITION/PURCHASE REQ. NO. | | 5. PROJECT NO.(If applicable) |
| 6. ISSUED BY NAVFAC SOUTHEAST IPT SOUTH CENTRAL BLDG 135, PO BOX 30 NAS JACKSONVILLE JACKSONVILLE FL 32212-0030 | CODE N69450 | 7. ADMINISTERED BY (If other than item 6) See Item 6 | | |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code) | | X | 9A. AMENDMENT OF SOLICITATION NO. N69450-12-R-1758 | |
| | | X | 9B. DATED (SEE ITEM 11) 06-Dec-2011 | |
| | | | 10A. MOD. OF CONTRACT/ORDER NO. | |
| | | | 10B. DATED (SEE ITEM 13) | |
| CODE | FACILITY CODE | | | |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS | | | | |
| <input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. | | | | |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required) | | | | |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14. | | | | |
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. | | | | |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B). | | | | |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: | | | | |
| D. OTHER (Specify type of modification and authority) | | | | |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office. | | | | |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to: 1. Correct the citation for Item 3) of amendment 0002 (number of technical pages) to read Section 00100 Proposal Submission Instructions Part (a) third paragraph. 2. Delete and replace Section G409001 AIRFIELD LIGHTING Paragraph 2 per PPI #41 3. Delete and replace Section G4010 Electrical Distribution Paragraph 4 per PPI #43 4. Delete and replace Section G409004 Underground Electrical Conductors Paragraph 2 5. Add paragraph to end of Section G4010 Electrical Distribution | | | | |
| Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect. | | | | |
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) | | |
| | | TEL: | EMAIL: | |
| 15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign) | 15C. DATE SIGNED | 16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer) | | 16C. DATE SIGNED 12-Jan-2012 |

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0003

1) The citation for Item 3) of amendment 0002 (number of technical pages) is corrected to read Section 00100 Proposal Submission Instructions Part (a) third paragraph.

2) Section G409001 AIRFIELD LIGHTING Paragraph 2

Delete: Provide a start/stop (green/red) warning light system to notify people in the area that an aircraft will be landing on a nearby VL Pad. Provide a minimum of two (2) warning lights per VL pad, located approximately 500 feet away, in either direction of the VL pad. Coordinate exact spacing and location requirements with command.

Replace With: Provide a start/stop (green/red) warning light system to notify people in the area that an aircraft will be landing on a nearby VL Pad. Refer to Part 3, Section 3.2 for warning light system requirements. Coordinate exact spacing and location requirements with command.

3) Section G4010 Electrical Distribution Paragraph 4

Delete: Building 404 shall house the Constant Current Regulators, two per pad, for VL Pad 3. Building 404 is fed from three pole-mount 50kVA, 124701/7200V-480/277V transformers with the following load: A-phase is 210.6A, B-phase is 223.3A and C-phase is 200.2A. Remove and replace existing pole-mount 50kVA transformers with three new 100kVA pole-mount transformers. Provide all new feeders and connections as necessary for a complete and usable system. Power connection for VL Pad 3 regulators shall come from panel MDP located in Building 404. Provide new breakers, type to match existing, as necessary and utilize existing spare breakers where possible for new Regulators. Equipment located in 404 that is not currently in use shall be removed and turned over to Public Works.

Replace With: Building 404 shall house the Constant Current Regulators, two per pad, for VL Pad 3. Building 404 is fed from three pole-mount 50kVA, 124701/7200V-480/277V transformers with the following load: A-phase is 210.6A, B-phase is 223.3A and C-phase is 200.2A. Remove and replace existing pole-mount 50kVA transformers with three new 100kVA pole-mount transformers. Replace existing, 400A MDP with new 600A MCB panel. Transfer all existing loads to new panel. Provide all new feeders, conduit and connections as necessary for a complete and usable system. Power connection for VL Pad 3 regulators shall come from new 600A panel MDP located in Building 404. Provide new breakers, type to match existing, as necessary and utilize existing spare breakers where possible for new Regulators. Equipment located in 404 that is not currently in use shall be removed and turned over to Public Works.

4) Section G409004 Underground Electrical Conductors Paragraph 2

Delete: For demolition of CALA Pad No. 2, remove all associated lighting. Maintain and reroute lighting circuits for existing CALA Pads to remain, around new VL Pad 5 site. Maintain and reroute existing communication conduit around new VL Pad 5 site. All downtime for circuit rerouting shall be minimized and fully coordinated with Public Works and Airfield Operations.

Replace With: Remove all associated lighting for CALA Pad No. 2 to be demolished. For existing CALA Pads to remain, maintain and reroute existing lighting and power circuits around new VL Pad 5 site. Maintain and reroute existing 120SM fiber connection and install new 50pair copper connection, for existing CALA Pads to remain, around new VL Pad 5 site.

There are currently two telecom manholes, one located northeast and one located southwest of CALA Pad 2. Disconnect and pull fiber from building 1080 back to manhole located southwest of CALA Pad 2. Provide and install a new manhole between the existing manholes, northwest of new VL Pad 5. Provide and install (2) 4" conduits between the new and existing manholes. Utilizing new 4" conduit, route existing fiber from existing southwest manhole to new manhole and cut fiber. Splice new fiber in new manhole and route to building 1080 utilizing new 4" conduit between new manhole and existing northeast manhole and existing conduit from northeast manhole to building 1080. Reconnect new fiber at building 1080. Provide all equipment and materials necessary for a proper, complete and operating system.

There are currently three existing telephone pedestals: two for CALA Pad 911 boxes and one for ordnance buildup area northwest of CALA Pad 4. Provide and install two (2) 4" conduits from manholes to existing telephone pedestals. Provide and install new 50pair copper connection, via new and existing conduit and manholes, from building 1080 to telephone pedestals; feed through pedestals back to manhole system to maintain continuous run. Splice connections in existing telephone pedestals. Existing copper between pedestals and 911 call boxes shall remain. Make all final connections in building 1080. Provide all equipment and materials necessary for a proper, complete and operating system.

All downtime for circuit rerouting shall be minimized and fully coordinated with Public Works and Airfield Operations. All light fixtures that are not reused shall be turned over to public works.

5) Section G4010 Electrical Distribution – end of section

Add: Remove existing overhead electrical lines, currently located between VL pads 1 and VL Pad 2 site, and reroute underground. Remove existing four (4) poles, to include poles 1317, 1315 and 1303 back to tree line, where new underground routing shall begin. Provide and install all new 6" conduits, feeders, manholes, connections, etc. as required and necessary for a complete and functional system. Any required splices shall be made in manholes or in above ground splice boxes.

(End of Summary of Changes)