

**BID OPTION 001
BE1121M
FACILITY 572 & 575, REPLACE BALL PARK LIGHTING
MARINE CORPS AIR STATION, BEAUFORT, S. C.**

SPECIFIC WORK REQUIREMENTS:

Replace poles 3108 and 3116 with Class 4-45 treated poles and provide new cross arms.
Transfer all equipment and cables to new poles. Provide new pole grounds.