

AASF Addition No.2, Proj No. 450252  
 McEntire JNGB, SC National Guard  
 Eastover, SC

**Request For Substitution Approvals**

Request No.	Item Description	Approval	Reason
# A	Vault Door: Class 5 Security Armory Door and Frame Assembly by OVERLY Door Co.	Approved	
# B	Modified Bitumin Roofing: Tremco BURmastic Composite Ply Tremco Power Ply Premium FR Tremco Power Supreme FR Tremco Ice Coating	Approved	
# C	Manufactured Metal Roof Panels: By Fabral	Not Approved	After further review system does not meet specifications.
# D	Insulated Translucent Fiberglass Sandwich Panel Wall System: Guardian 275 Translucent Skylights and Curtain Wall	Approved	
# E	Manufactured Metal Roof Panels: by CBC of Charleston	Not Approved	Information submitted insufficient to compare with specified item.
# F	Fall Arrestor System: By Guardian Fall Protection Inc.	Not Approved	Information submitted insufficient to compare with specified item.
# G	Metal Roof Panels by CMP Inc.	Not Approved	Warrenty info indicates 20 yr limited in lieu of 30 year NDL warrenty
# H	Genorators: Comparable products by Generac	Approved	
# I	Rose Talbert Paints	Approved	
# J	Workbenches by Formaspace	Approved	
# K	Workbenches by One Point Solutions	Approved	
# L	Metal Roof Panels by Tremco	Not Approved	Information submitted insufficient to compare with specified item.
# M	Insulated Core Metal Wall Panels by MetlSpan	Not Approved	Not correct finish.
# N	Roofing by Sarnafil	Not Approved	Not meeting specs.
# O	Flooring Systems by Sikafloor	Approved	
# P	RESERVED		
# Q	Vault Door by Custom Vault	Approved	
# R	Generator Transfer Switch by Kohler	Approved	